


Energy Efficiency Certificate

Issued by Liftinstituut B.V.

Certificate number	NL20EPCL112838
Object number.	-
Address	Utmarksvägen 13 802 91, Gävle, Sweden
User category	1
No. of days in use per year	365
Product description	Low speed lift
Nominal load	630 kg
Nominal speed	0,15 m/s
Trademark, type, serial no.	Cibes, Kalea C90 112838
Name and address installer	Cibes Lift Group AB Utmarksvägen 13 802 91, Gävle, Sweden
Name and address owner certificate	Cibes Lift Group AB Utmarksvägen 13 802 91, Gävle, Sweden
Certificate issued on the basis of the following requirements	EN-ISO 25745-2:2015
Performance level for running	7
Performance level idle	1
Performance level standby 5 min	1
Performance level standby 30 min	1
Date of examination	12-03-2020
Annexes to this certificate	Report of Energy Efficiency measurement NL20EPCL112838

Conclusion




The energy label shown is based on the energy efficiency measurement for the above mentioned low speed lift

Issued in Amsterdam

Date of issue

25-03-2020


ing P.J. Peeters
Manager Certification


Certification decision by